

**TITLE 3: HUMAN RESOURCES**  
**DIVISION 5: PUBLIC SAFETY**

**§ 5330. Clear Space Around Hydrants.**

A 3-foot clear space shall be maintained around the circumference of fire hydrants except as otherwise required or approved.

**Source:** PL 12-74, § 11.